

# Wyniki - Nastawy

Typ	Numer		Pom.	Symbol	Nastawa	Aut.	dn	G	Kv	dP	Lokalizacja elementu
	Pion	Dział.					[mm]	[kg/s]	[m3/h]	[Pa]	
Z		100	17020	RTD-N-P	4	0.33	15	0.016	0.184	10753	Gałązka grzejnika dn 15
Z		100	19004	RTD-N-P	4.5	0.32	15	0.018	0.206	10698	Gałązka grzejnika dn 15
Z		100	15024	RTD-N-P	3.5	0.47	15	0.014	0.135	15577	Gałązka grzejnika dn 15
Z		100	15023	RTD-N-P	3.5	0.47	15	0.014	0.135	15579	Gałązka grzejnika dn 15
Z		100	4001	RTD-N-P	2	0.84	15	0.007	0.074	12715	Gałązka grzejnika dn 15
Z		100	6005	RTD-N-P	3	0.84	15	0.011	0.112	12669	Gałązka grzejnika dn 15
Z		103	7001	RTD-N-P	3.5	0.88	15	0.013	0.127	13468	Gałązka grzejnika dn 15
Z		103	13004	RTD-N-P	1.5	0.88	15	0.012	0.052	79444	Gałązka grzejnika dn 15
Z		103	6006	RTD-N-P	3	0.84	15	0.011	0.116	11833	Gałązka grzejnika dn 15
Z		103	7008	RTD-N-P	3.5	0.83	15	0.013	0.135	11943	Gałązka grzejnika dn 15
Z		103	7007	RTD-N-P	3.5	0.84	15	0.013	0.135	11941	Gałązka grzejnika dn 15
Z		103	12003	RTD-N-P	3.5	0.82	15	0.011	0.122	12050	Gałązka grzejnika dn 15
Z		103	8002	RTD-N-P	2	0.86	15	0.008	0.080	12557	Gałązka grzejnika dn 15
Z		103	9004	RTD-N-P	2.5	0.86	15	0.009	0.090	12535	Gałązka grzejnika dn 15
Z		103	7002	RTD-N-P	3.5	0.82	15	0.013	0.140	11019	Gałązka grzejnika dn 15
Z		103	5001	RTD-N-P	2.5	0.83	15	0.009	0.100	11073	Gałązka grzejnika dn 15
Z		103	9003	RTD-N-P	2.5	0.83	15	0.009	0.096	11112	Gałązka grzejnika dn 15
Z		103	8001	RTD-N-P	2.5	0.83	15	0.008	0.085	11120	Gałązka grzejnika dn 15
Z		103	14001	RTD-N-P	3.5	0.84	15	0.013	0.149	11092	Gałązka grzejnika dn 15
Z		103	12001	RTD-N-P	3.5	0.84	15	0.011	0.128	11110	Gałązka grzejnika dn 15
Z		103	9002	RTD-N-P	2.5	0.83	15	0.009	0.096	10914	Gałązka grzejnika dn 15
Z		203	13002	RTD-N-P	3.5	0.82	15	0.012	0.129	12716	Gałązka grzejnika dn 15
Z		203	16030	RTD-N-P	3.5	0.82	15	0.015	0.159	12653	Gałązka grzejnika dn 15
Z		203	14012	RTD-N-P	3	0.58	15	0.013	0.114	18882	Gałązka grzejnika dn 15
Z		203	14011	RTD-N-P	3	0.58	15	0.013	0.114	18880	Gałązka grzejnika dn 15
Z		203	5007	RTD-N-P	2.5	0.84	15	0.009	0.095	12242	Gałązka grzejnika dn 15
Z		203	4002	RTD-N-P	2	0.86	15	0.007	0.077	11957	Gałązka grzejnika dn 15
Z		203	22002	RTD-N-P	4.5	0.83	15	0.021	0.222	12306	Gałązka grzejnika dn 15
Z		203	22001	RTD-N-P	4.5	0.84	15	0.021	0.222	12311	Gałązka grzejnika dn 15
Z		203	15020	RTD-N-P	3.5	0.82	15	0.014	0.150	12649	Gałązka grzejnika dn 15
Z		203	5003	RTD-N-P	2.5	0.82	15	0.009	0.094	12588	Gałązka grzejnika dn 15
Z		203	16034	RTD-N-P	4	0.81	15	0.015	0.163	12150	Gałązka grzejnika dn 15
Z		203	12004	RTD-N-P	3.5	0.80	15	0.011	0.123	11932	Gałązka grzejnika dn 15
Z		203	14009	RTD-N-P	3.5	0.75	15	0.013	0.150	10942	Gałązka grzejnika dn 15
Z		203	14008	RTD-N-P	3.5	0.75	15	0.013	0.150	10948	Gałązka grzejnika dn 15
Z		203	16032	RTD-N-P	4	0.82	15	0.015	0.161	12357	Gałązka grzejnika dn 15
Z		203	16031	RTD-N-P	4	0.82	15	0.015	0.161	12360	Gałązka grzejnika dn 15
Z		203	16029	RTD-N-P	3.5	0.85	15	0.015	0.157	13094	Gałązka grzejnika dn 15
Z		203	15017	RTD-N-P	3.5	0.85	15	0.014	0.147	13112	Gałązka grzejnika dn 15
Z		203	15013	RTD-N-P	3.5	0.85	15	0.014	0.140	14414	Gałązka grzejnika dn 15

# Wyniki - Nastawy

Typ	Numer		Pom.	Symbol	Nastawa	Aut.	dn	G	Kv	dP	Lokalizacja elementu	
	Pion	Dział.					[mm]	[kg/s]	[m3/h]	[Pa]		
Z		203	16025	RTD-N-P	3.5	0.85	15	0.015	0.149	14417	Gałązka grzejnika	dn 15
Z		203	17013	RTD-N-P	3.5	0.86	15	0.016	0.158	14477	Gałązka grzejnika	dn 15
Z		203	3005	RTD-N-P	1.5	0.83	15	0.005	0.055	12968	Gałązka grzejnika	dn 15
Z		203	6002	RTD-N-P	3	0.83	15	0.011	0.111	12899	Gałązka grzejnika	dn 15
Z		203	10003	RTD-N-P	2.5	0.87	15	0.010	0.094	14119	Gałązka grzejnika	dn 15
Z		203	10001	RTD-N-P	2.5	0.86	15	0.010	0.094	14079	Gałązka grzejnika	dn 15
Z		203	10002	RTD-N-P	2.5	0.86	15	0.010	0.095	14081	Gałązka grzejnika	dn 15
Z		203	7003	RTD-N-P	3.5	0.82	15	0.013	0.130	12824	Gałązka grzejnika	dn 15
Z		203	9006	RTD-N-P	2.5	0.82	15	0.009	0.089	12888	Gałązka grzejnika	dn 15
Z		203	5002	RTD-N-P	2.5	0.84	15	0.009	0.094	12455	Gałązka grzejnika	dn 15
Z		203	14004	RTD-N-P	3.5	0.85	15	0.013	0.138	12869	Gałązka grzejnika	dn 15
Z		203	9005	RTD-N-P	2.5	0.86	15	0.009	0.089	12939	Gałązka grzejnika	dn 15
Z		203	16014	RTD-N-P	4	0.86	15	0.015	0.165	11841	Gałązka grzejnika	dn 15
Z		203	12002	RTD-N-P	3.5	0.86	15	0.011	0.123	11889	Gałązka grzejnika	dn 15
Z		203	14003	RTD-N-P	3.5	0.86	15	0.013	0.144	11865	Gałązka grzejnika	dn 15
Z		203	20002	RTD-N-P	4	0.85	15	0.019	0.194	13330	Gałązka grzejnika	dn 15
Z		203	19001	RTD-N-P	4	0.85	15	0.018	0.184	13381	Gałązka grzejnika	dn 15
Z		203	16013	RTD-N-P	3.5	0.87	15	0.015	0.154	13591	Gałązka grzejnika	dn 15
Z		203	16010	RTD-N-P	4	0.82	15	0.015	0.169	11252	Gałązka grzejnika	dn 15
Z		203	15004	RTD-N-P	3.5	0.83	15	0.014	0.158	11270	Gałązka grzejnika	dn 15
Z		203	16008	RTD-N-P	4	0.82	15	0.015	0.169	11213	Gałązka grzejnika	dn 15
Z		203	3001	RTD-N-P	1.5	0.83	15	0.005	0.059	11353	Gałązka grzejnika	dn 15
Z		203	3002	RTD-N-P	1.5	0.83	15	0.005	0.059	11353	Gałązka grzejnika	dn 15
Z		203	17004	RTD-N-P	4	0.81	15	0.016	0.182	10973	Gałązka grzejnika	dn 15
Z		203	16006	RTD-N-P	4	0.81	15	0.015	0.171	10996	Gałązka grzejnika	dn 15
Z		203	17003	RTD-N-P	3	0.85	15	0.016	0.114	27717	Gałązka grzejnika	dn 15
Z		203	20001	RTD-N-P	3.5	0.85	15	0.019	0.135	27637	Gałązka grzejnika	dn 15
Z		203	15002	RTD-N-P	3	0.63	15	0.014	0.117	20654	Gałązka grzejnika	dn 15
Z		203	16002	RTD-N-P	3.5	0.63	15	0.015	0.125	20650	Gałązka grzejnika	dn 15
Z		203	18001	RTD-N-P	4	0.38	15	0.017	0.180	12549	Gałązka grzejnika	dn 15
Z		203	15001	RTD-N-P	3.5	0.38	15	0.014	0.150	12522	Gałązka grzejnika	dn 15
Z		203	16001	RTD-N-P	3.5	0.39	15	0.015	0.160	12557	Gałązka grzejnika	dn 15
Z		303	18005	RTD-N-P	3.5	0.58	15	0.017	0.145	19309	Gałązka grzejnika	dn 15
Z		303	17018	RTD-N-P	3.5	0.59	15	0.016	0.137	19335	Gałązka grzejnika	dn 15
Z		303	6007	RTD-N-P	3	0.84	15	0.011	0.112	12646	Gałązka grzejnika	dn 15
Z		303	15022	RTD-N-P	3.5	0.76	15	0.014	0.157	11521	Gałązka grzejnika	dn 15
Z		303	15021	RTD-N-P	3.5	0.76	15	0.014	0.157	11516	Gałązka grzejnika	dn 15
Z		303	8004	RTD-N-P	2	0.80	15	0.008	0.080	12579	Gałązka grzejnika	dn 15
Z		303	5004	RTD-N-P	2.5	0.80	15	0.009	0.094	12558	Gałązka grzejnika	dn 15
Z		303	14010	RTD-N-P	3.5	0.83	15	0.013	0.137	13195	Gałązka grzejnika	dn 15

# Wyniki - Nastawy

Typ	Numer		Pom.	Symbol	Nastawa	Aut.	dn	G	Kv	dP	Lokalizacja elementu	
	Pion	Dział.					[mm]	[kg/s]	[m3/h]	[Pa]		
Z		303	11002	RTD-N-P	3	0.74	15	0.010	0.115	11447	Gałązka grzejnika	dn 15
Z		303	12005	RTD-N-P	3.5	0.74	15	0.011	0.126	11429	Gałązka grzejnika	dn 15
Z		303	15019	RTD-N-P	3.5	0.73	15	0.014	0.160	11031	Gałązka grzejnika	dn 15
Z		303	16033	RTD-N-P	4	0.73	15	0.015	0.171	10976	Gałązka grzejnika	dn 15
Z		303	9008	RTD-N-P	2.5	0.82	15	0.009	0.089	12773	Gałązka grzejnika	dn 15
Z		303	11001	RTD-N-P	3	0.82	15	0.010	0.109	12749	Gałązka grzejnika	dn 15
Z		303	15018	RTD-N-P	3.5	0.72	15	0.014	0.156	11549	Gałązka grzejnika	dn 15
Z		303	18003	RTD-N-P	4	0.73	15	0.017	0.187	11688	Gałązka grzejnika	dn 15
Z		303	18002	RTD-N-P	4	0.73	15	0.017	0.187	11685	Gałązka grzejnika	dn 15
Z		303	15014	RTD-N-P	3.5	0.70	15	0.014	0.153	12134	Gałązka grzejnika	dn 15
Z		303	15016	RTD-N-P	3.5	0.70	15	0.014	0.153	12154	Gałązka grzejnika	dn 15
Z		303	9007	RTD-N-P	2.5	0.71	15	0.009	0.091	12335	Gałązka grzejnika	dn 15
Z		303	3006	RTD-N-P	1.5	0.75	15	0.005	0.057	12037	Gałązka grzejnika	dn 15
Z		303	3007	RTD-N-P	1.5	0.75	15	0.005	0.057	12037	Gałązka grzejnika	dn 15
Z		303	6003	RTD-N-P	3	0.75	15	0.011	0.115	11989	Gałązka grzejnika	dn 15
Z		303	16024	RTD-N-P	4	0.68	15	0.015	0.168	11412	Gałązka grzejnika	dn 15
Z		303	15010	RTD-N-P	3.5	0.68	15	0.014	0.158	11345	Gałązka grzejnika	dn 15
Z		303	14007	RTD-N-P	3.5	0.68	15	0.013	0.147	11380	Gałązka grzejnika	dn 15
Z		303	16023	RTD-N-P	4	0.71	15	0.015	0.167	11491	Gałązka grzejnika	dn 15
Z		303	16022	RTD-N-P	4	0.71	15	0.015	0.167	11494	Gałązka grzejnika	dn 15
Z		303	6001	RTD-N-P	3	0.84	15	0.011	0.112	12764	Gałązka grzejnika	dn 15
Z		303	16020	RTD-N-P	4	0.70	15	0.015	0.172	10827	Gałązka grzejnika	dn 15
Z		303	17010	RTD-N-P	4	0.69	15	0.016	0.184	10683	Gałązka grzejnika	dn 15
Z		303	16019	RTD-N-P	4	0.69	15	0.015	0.173	10733	Gałązka grzejnika	dn 15
Z		303	16016	RTD-N-P	4	0.70	15	0.015	0.180	9945	Gałązka grzejnika	dn 15
Z		303	16015	RTD-N-P	4	0.69	15	0.015	0.181	9826	Gałązka grzejnika	dn 15
Z		303	17009	RTD-N-P	4	0.69	15	0.016	0.192	9833	Gałązka grzejnika	dn 15
Z		303	14002	RTD-N-P	3.5	0.68	15	0.013	0.150	11000	Gałązka grzejnika	dn 15
Z		303	13001	RTD-N-P	3.5	0.68	15	0.012	0.139	11034	Gałązka grzejnika	dn 15
Z		303	15007	RTD-N-P	3.5	0.69	15	0.014	0.160	11068	Gałązka grzejnika	dn 15
Z		303	15005	RTD-N-P	4	0.73	15	0.014	0.165	10370	Gałązka grzejnika	dn 15
Z		303	16011	RTD-N-P	4	0.73	15	0.015	0.176	10347	Gałązka grzejnika	dn 15
Z		303	17006	RTD-N-P	4	0.77	15	0.016	0.182	10905	Gałązka grzejnika	dn 15
Z		303	3003	RTD-N-P	1.5	0.78	15	0.005	0.060	11073	Gałązka grzejnika	dn 15
Z		303	3004	RTD-N-P	1.5	0.78	15	0.005	0.060	11073	Gałązka grzejnika	dn 15
Z		303	16007	RTD-N-P	4	0.79	15	0.015	0.171	11013	Gałązka grzejnika	dn 15
Z		303	17005	RTD-N-P	4	0.78	15	0.016	0.182	10988	Gałązka grzejnika	dn 15
Z		303	15003	RTD-N-P	3	0.76	15	0.014	0.106	25260	Gałązka grzejnika	dn 15
Z		303	9001	RTD-N-P	2	0.77	15	0.009	0.063	25342	Gałązka grzejnika	dn 15
Z		303	16004	RTD-N-P	3.5	0.64	15	0.015	0.124	21001	Gałązka grzejnika	dn 15

# Wyniki - Nastawy

Typ	Numer		Pom.	Symbol	Nastawa	Aut.	dn	G	Kv	dP	Lokalizacja elementu	
	Pion	Dział.					[mm]	[kg/s]	[m3/h]	[Pa]		
Z		303	16005	RTD-N-P	3.5	0.64	15	0.015	0.124	21033	Gałązka grzejnika	dn 15
Z		303	16003	RTD-N-P	3.5	0.64	15	0.015	0.123	21127	Gałązka grzejnika	dn 15
Z		303	17001	RTD-N-P	4	0.41	15	0.016	0.164	13542	Gałązka grzejnika	dn 15
Z		303	17002	RTD-N-P	4	0.41	15	0.016	0.164	13570	Gałązka grzejnika	dn 15
Z		403	16037	RTD-N-P	4	0.74	15	0.015	0.167	11541	Gałązka grzejnika	dn 15
Z		403	16036	RTD-N-P	4	0.74	15	0.015	0.167	11544	Gałązka grzejnika	dn 15
Z		403	5006	RTD-N-P	2.5	0.79	15	0.009	0.093	12871	Gałązka grzejnika	dn 15
Z		403	5005	RTD-N-P	2.5	0.79	15	0.009	0.093	12872	Gałązka grzejnika	dn 15
Z		403	10004	RTD-N-P	2.5	0.84	15	0.010	0.096	13686	Gałązka grzejnika	dn 15
Z		403	16035	RTD-N-P	4	0.72	15	0.015	0.168	11461	Gałązka grzejnika	dn 15
Z		403	13003	RTD-N-P	3.5	0.73	15	0.012	0.136	11525	Gałązka grzejnika	dn 15
Z		403	18004	RTD-N-P	4	0.67	15	0.017	0.192	11029	Gałązka grzejnika	dn 15
Z		403	17016	RTD-N-P	4	0.66	15	0.016	0.182	10929	Gałązka grzejnika	dn 15
Z		403	17017	RTD-N-P	4	0.67	15	0.016	0.182	10960	Gałązka grzejnika	dn 15
Z		403	17015	RTD-N-P	4	0.72	15	0.016	0.176	11735	Gałązka grzejnika	dn 15
Z		403	17014	RTD-N-P	4	0.72	15	0.016	0.176	11738	Gałązka grzejnika	dn 15
Z		403	16027	RTD-N-P	4	0.66	15	0.015	0.166	11695	Gałązka grzejnika	dn 15
Z		403	16028	RTD-N-P	4	0.66	15	0.015	0.166	11727	Gałązka grzejnika	dn 15
Z		403	16026	RTD-N-P	4	0.67	15	0.015	0.165	11821	Gałązka grzejnika	dn 15
Z		403	7006	RTD-N-P	3.5	0.72	15	0.013	0.135	11814	Gałązka grzejnika	dn 15
Z		403	7004	RTD-N-P	3.5	0.71	15	0.013	0.136	11739	Gałązka grzejnika	dn 15
Z		403	7005	RTD-N-P	3.5	0.71	15	0.013	0.136	11757	Gałązka grzejnika	dn 15
Z		403	17012	RTD-N-P	4	0.64	15	0.016	0.182	11015	Gałązka grzejnika	dn 15
Z		403	15011	RTD-N-P	4	0.64	15	0.014	0.161	10971	Gałązka grzejnika	dn 15
Z		403	15012	RTD-N-P	3.5	0.64	15	0.014	0.160	11050	Gałązka grzejnika	dn 15
Z		403	14006	RTD-N-P	3.5	0.67	15	0.013	0.148	11187	Gałązka grzejnika	dn 15
Z		403	15009	RTD-N-P	3.5	0.67	15	0.014	0.159	11187	Gałązka grzejnika	dn 15
Z		403	14005	RTD-N-P	3.5	0.68	15	0.013	0.148	11288	Gałązka grzejnika	dn 15
Z		403	8003	RTD-N-P	2	0.84	15	0.008	0.078	13234	Gałązka grzejnika	dn 15
Z		403	17011	RTD-N-P	4	0.68	15	0.016	0.183	10815	Gałązka grzejnika	dn 15
Z		403	16021	RTD-N-P	4	0.68	15	0.015	0.172	10845	Gałązka grzejnika	dn 15
Z		403	16017	RTD-N-P	4	0.68	15	0.015	0.180	9949	Gałązka grzejnika	dn 15
Z		403	16018	RTD-N-P	4	0.68	15	0.015	0.180	9980	Gałązka grzejnika	dn 15
Z		403	17007	RTD-N-P	4	0.63	15	0.016	0.186	10466	Gałązka grzejnika	dn 15
Z		403	17008	RTD-N-P	4	0.63	15	0.016	0.186	10482	Gałązka grzejnika	dn 15
Z		403	15008	RTD-N-P	4	0.64	15	0.014	0.163	10640	Gałązka grzejnika	dn 15
Z		403	15006	RTD-N-P	4	0.72	15	0.014	0.164	10446	Gałązka grzejnika	dn 15
Z		403	16012	RTD-N-P	4	0.72	15	0.015	0.176	10423	Gałązka grzejnika	dn 15
Z		403	16009	RTD-N-P	4	0.77	15	0.015	0.169	11303	Gałązka grzejnika	dn 15
Z			19003	RTD-N-P	4.5	0.31	15	0.018	0.213	9970	Gałązka grzejnika	dn 15

# Wyniki - Nastawy

Typ	Numer		Pom.	Symbol	Nastawa	Aut.	dn	G	Kv	dP	Lokalizacja elementu
	Pion	Dział.					[mm]	[kg/s]	[m3/h]	[Pa]	
Z			19002	RTD-N-P	4.5	0.31	15	0.018	0.213	9969	Gałązka grzejnika dn 15
Z			17019	RTD-N-P	3.5	0.46	15	0.016	0.156	14841	Gałązka grzejnika dn 15
Z			16038	RTD-N-P	3.5	0.46	15	0.015	0.147	14866	Gałązka grzejnika dn 15
Z			6004	RTD-N-P	3	0.84	15	0.011	0.114	12339	Gałązka grzejnika dn 15
P		101	16031	ASV-PV	13		15	0.061	0.326	47161	Na pionie ...: dn 15
P		101	16030	ASV-PV	12		15	0.092	0.471	51013	Na pionie ...: dn 15
P		101	3002	ASV-PV	14		15	0.068	0.422	35238	Na pionie ...: dn 15
P		101	5002	ASV-PV	14		15	0.027	0.133	56960	Na pionie ...: dn 15
P		101	9005	ASV-PV	12		15	0.116	0.586	53130	Na pionie ...: dn 20
P		101	22001	ASV-PV	12		15	0.126	0.660	49327	Na pionie ...: dn 20
P		101	14003	ASV-PV	12		15	0.162	0.869	46923	Na pionie ...: dn 20
P		101	16013	ASV-PV	10		15	0.152	0.902	38173	Na pionie ...: dn 20
P		101	15004	ASV-PV	13		15	0.114	0.679	37695	Na pionie ...: dn 20
P		101	16006	ASV-PV	14		15	0.072	0.454	33489	Na pionie ...: dn 15
P		101	5007	ASV-PV	14		15	0.030	0.197	32078	Na pionie ...: dn 15
P		101	6006	ASV-PV PLUS	5		25	0.404	4.000	13710	Na pionie ...: dn 25
P		101	15017	ASV-PV	12		15	0.096	0.486	53023	Na pionie ...: dn 20
P		101	17013	ASV-PV	10		15	0.129	0.638	54931	Na pionie ...: dn 20
P		101	12004	ASV-PV	13		15	0.076	0.357	61658	Na pionie ...: dn 15
P		101	6002	ASV-PV	12		15	0.098	0.450	63970	Na pionie ...: dn 20
P		101	10002	ASV-PV	11		15	0.116	0.525	66145	Na pionie ...: dn 20
P		101	5003	ASV-PV	13		15	0.058	0.265	64043	Na pionie ...: dn 15
P		101	9006	ASV-PV	12		15	0.093	0.422	65150	Na pionie ...: dn 15
P			14009	ASV-PV	13		15	0.085	0.446	48833	Na pionie ...: dn 15